



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2000504
Permit #:	00242-2026ABN
Request Rec'd:	03/04/2026
Approval Date:	03/05/2026 DS
Permit Expires:	09/08/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Village of Elk Grove Village 901 Wellington Avenue Elk Grove Village, IL 60007 Cook County Contact: Scott Santille 847/357-4004	FACILITY - name and address where tanks are located: Fire Station 901 Wellington Avenue Elk Grove Village, IL 60007 Cook County Contact: Mike Ohara 708/734-8800
---	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	4,000	Gasoline - Regular	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

UST to be abandoned in tank because of proximity to utilities and building foundation.

Location of Tanks Being Abandoned

Tank is located in close proximity to a building, as shown in site plan. Attempting to remove the tank would likely undermine the structural integrity of the building.

Location of Piping Being Abandoned

No piping was mentioned in the permit to be abandoned, nor was any shown on the drawing, therefore a separate removal permit must be submitted to remove the piping.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 312/505-6763 Email: alock@rwcollins.com Contractor License # IL772 Exp. 2/9/2028

Sincerely,

Daniel Starks