



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	6021653
Permit #:	00126-2026UPG
Request Rec'd:	02/02/2026
Approval Date:	02/02/2026 DS
Amended Date:	03/09/2026 SB
Permit Expires:	08/04/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Shiv & Diya Enterprise, Inc. 1109 12th Street Carlyle, IL 62231 Clinton County Contact: Jay Patel 423/800-3940	FACILITY - name and address where tanks are located: Carlyle Food Mart 1109 12th Street Carlyle, IL 62231 Clinton County 08-07-13-454-004 Contact: Mick Patel 423/800-3940
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Premium	5,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

Try and remove seized overfill and replace, if we need to replace spill bucket at that time we will. If we can remove the seized overfill and not damage the spill bucket we will retest and not replace.


Special Contingencies

Amendment Reason:

Didn't have to replace spill bucket, filing a like for like.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: 812/425-4137 Email: mark.k@hici4.com Contractor License # IL646 Exp. 7/3/2026

Sincerely,



Daniel Starks