



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2015461
Permit #:	00266-2026ABN
Request Rec'd:	03/03/2026
Approval Date:	03/11/2026 DS
Permit Expires:	09/11/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Nice Group, Inc. 1001 East Algonquin Rd. Arlington Heights, IL 60005 Cook County Contact: Siny Thomas 847/593-7166</p>	<p>FACILITY - name and address where tanks are located: TSS Oil, Inc. 1651 Algonquin Road 1625 W. Algonquin Road Mount Prospect, IL 60056 Cook County 08-23-101-016-0000 Contact: Siny Thomas 847/593-7166</p>
---	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
3	4,000	Gasoline - Regular	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Abandonment of the UST because it is in an active UST pit and removal would jeopardize the remaining active USTs. The existing piping to be capped and left in place. Removal of the piping needs to be abandoned because it is next to active piping.

Location of Tanks Being Abandoned

Tank is located in an active tank field as shown in attached drawing

Location of Piping Being Abandoned

Piping shares a trench with active piping as shown in attached drawing

CONTAMINATED SITE!

IEMA Number

2026-0120

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Orivne, Inc. PO Box 46249 Chicago, IL 606460249</p>	<p>Contact Person: Mike Leyden Phone: 312/656-2009 Email: mleyden@orivne.us Contractor License # IL002408 Exp. 5/1/2027</p>

Sincerely,

Daniel J. Starks

Daniel Starks