



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2000973
Permit #:	00272-2026UPG
Request Rec'd:	03/11/2026
Approval Date:	03/12/2026 DS
Permit Expires:	09/14/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Warren Township High School District 121 500 O'Plaine Road Gurnee, IL 60031 Lake County Contact: Mike Rizzo 847/599-4787	<b>FACILITY</b> - name and address where tanks are located: Warren Township High School District 121 500 O'Plaine Road Gurnee, IL 60031 Lake County Contact: Ken Bergeron 847/599-4787
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	2,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron	Replacing - Piping - Fiberglass Single Wall Piping A.O. Smith

**Dispensers on the Permit**

Dispenser	Action
1	Sump / Sensors Changing

**Dispenser 1 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Summary of Work**

IPT to add a new UDC under the dispenser and double-walled piping

**Special Contingencies**

**NOTE: Piping is European suction, therefore it does not require sump sensors to be installed**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Interstate Pump and Tank, LLC 901 Niagara Street Waukesha, WI 531863817	Contact Person: Luke Garland Phone: 262/524-8494 Email: dan@interstatepumpandtank.com Contractor License # IL002423 Exp. 6/19/2027

Sincerely,

*Daniel S. Starks*

Daniel Starks

**For Office Use Only**

**Dispenser 1 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Dispenser	Not Installed UDC Sump	Removing