



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	6036442
Permit #:	00267-2026UPG
Request Rec'd:	03/10/2026
Approval Date:	03/11/2026 DS
Amended Date:	03/12/2026 DS
Permit Expires:	09/11/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Rudra Raj LLC 104 W. 4th Street Hoffman, IL 62250 (None) County Contact: Raj Patel 708/789-3903	FACILITY - name and address where tanks are located: KKR Hoffman Inc. - Hoffman Supermarket 104 W. 4th Street Hoffman, IL 62250 Clinton County 14-13-12-355-001 Contact: Raj Patel 708/789-3903
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	6,000	Currently in use	Federal
3	B-11	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO One	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO One	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO One	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500

Summary of Work

We are installing a new Franklin Fueling Evo One ATG system to replace the existing EMCO. We are also replacing the existing dispensers. All connections to be made above the shear valve. We will replace the emergency valve on the premium at dispenser 1/2. The emergency valve is not closing off properly. There are existing dispenser sumps.


Special Contingencies

Amendment Reason:

An emergency valve was discovered that does not shut off and needs to be replaced

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: tsmith@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2028

Sincerely,



Daniel Starks