



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2011007 |
| Permit #: | 00279-2026UPG |
| Request Rec'd: | 03/04/2026 |
| Approval Date: | 03/14/2026 DS |
| Permit Expires: | 09/15/2026 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois State Toll Highway Authority 2700 Ogden Avenue Downers Grove, IL 60515 Du Page County Contact: James Ryan 847/212-4024 | FACILITY - name and address where tanks are located: ISTHA M01 Maintenance Garage 127th & Cicero on I-294 I-294 MP 12.5 Alsip, IL 60658 Cook County Contact: Porto Sam 708/241-6800 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 10 | Diesel Fuel | 10,000 | Currently in use | Federal |
| 11 | E85 | 10,000 | Currently in use | Federal |
| 12 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 13 | Diesel Fuel | 12,000 | Currently in use | Federal |

Tank 10 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 11 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 12 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 13 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Summary of Work


this permit application is only to remove the CSLD part of their leak detection. They do not have nor have they ever had CSLD at this site. They use interstitial monitoring

Thanks

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|---|
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2028 |

Sincerely,



Daniel Starks