



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2045956 |
| Permit #: | 00281-2026UPG |
| Request Rec'd: | 03/13/2026 |
| Approval Date: | 03/14/2026 DS |
| Permit Expires: | 09/15/2026 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| <p>OWNER OF TANKS - Corporation, partnership, or other business entity: Meyer Material Company 1300 S. IL Route 31 South Elgin, IL 60050 Kane County Contact: Mike Shimerdla 847/417-1755</p> | <p>FACILITY - name and address where tanks are located: Ozinga Bros, Inc. 10101 IL Route 31 Algonquin, IL 60102 McHenry County 19-22-251-004 Contact: Mike Shimerdla 815/331-7200</p> |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 1 | Diesel Fuel | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|------------------|----------|
| Overfill Prevention Device | Overfill Alarm | Removing |


Summary of Work

REMOVING OVERFILL ALARM AS METHOD OF OVERFILL PREVENTION. OVERFILL DROP TUBE STILL PRESENT

Special Contingencies

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Superior Petroleum Marketers, Inc. 2336 Albright Lane P. O.Box 4648 Wheaton, IL 601894648 | Contact Person: Steve Tuttle Phone: 630/588-1198 Email: tuttle.steve11@gmail.com Contractor License # IL2087 Exp. 2/4/2028 |

Sincerely,



Daniel Starks