



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	3016233
Permit #:	00227-2026INS
Request Rec'd:	02/25/2026
Approval Date:	02/26/2026 DS
Amended Date:	03/18/2026 DS
Permit Expires:	08/26/2026

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Evergreen FS, Inc. P.O. Box 1367 Bloomington, IL 61702 McLean County Contact: Bob Eichelberger 309/275-8725</p>	<p>FACILITY - name and address where tanks are located: Evergreen FS, Inc. El Paso 201 East Main Street El Paso, IL 61738 Woodford County Contact: Ron Armstrong 309/923-8791</p>
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	15,000	Tank Not Installed	Federal
7	Diesel Fuel	10,000	Tank Not Installed	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Ball Valves	New
Piping	Extractor Fitting Valves	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Fiberglass Single Wall Piping Vent	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	New
Tank	Fiberglass Double Wall KBK Industries	New

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Ball Valves	New
Piping	Extractor Fitting Valves	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Fiberglass Single Wall Piping Vent	New
Piping	Flex Connector Steel	New
Piping	Other Steel Riser	New
Piping	Other Submersible Pump	New
Piping	Shear Valves	New
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	New
Tank	Fiberglass Double Wall KBK Industries	New

Dispensers on the Permit

Dispenser	Action
Diesel	Replacing - Diesel
Gas	Replacing - Gas

Dispenser Diesel Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser Gas Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor	Replacing - Leak Detect - Piping - Sump Sensor

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions. There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

The current tanks, canopy, dispensers, and islands will be removed. We will form and pour (2) new canopy footers. We will excavate tank hole, install filter fabric, and place 1' of approved gravel at the base. We will install deadmen anchors and install (1) 8' diameter 15,000 gallon UNL KBK tank and (1) 8' diameter 10,000 gallon diesel KBK tank under IL OSFM supervision. We will then anchor the tank to the deadmen and backfill with approved gravel. The tank will be ballasted with water until the job is complete. We will install Bravo fiberglass single wall tank top sumps and Red Jacket submersible pumps. We will run NOV fiberglass double wall product pipe, and NOV single wall vent pipe. The vents will be installed 12' above finished grade. The UDC's will be Bravo single wall fiberglass with OPW shear valves and Franklin Fueling flexes. For collision protection we will install River Side S.S. islands and 6" bollards. For tank monitoring we will be using a TLS 450 Plus. Fuel levels will be monitored by Veeder Root Mag Plus probes. Line leak detection will be achieved using Veeder Root DPLLD's. We will use Veeder Root sump sensors and Veeder Root solid state non discriminating interstitial sensors. Overfill prevention and spill prevention will be achieved by OPW overfill drop tubes and OPW double wall spill buckets. An OPW single wall spill bucket will be installed for vapor recovery. All product pipe, vent pipe, and containment sumps will be air and water tested under IL OSFM supervision. A new fire detection system will be installed for self-service fueling. After primary and secondary inspections are completed, we will backfill all trenches, islands, and tank hole with approved gravel. OPW and Morrison manways will be installed over tank top sumps, interstitial risers, probe risers, and vent risers. Once all manways, islands, and bollards are set to grade we will pour back all concrete. Fuel dispensing will be achieved by Gilbarco 700 S dispensers, Eagle hose, OPW breakaways, OPW swivels, and OPW nozzles. Before final inspection is set up with IL OSFM dispensers will be purged and calibrated.

Special Contingencies

NOTES: Vents must meet section 175.440 of our rules. Dispensers must be at least 10' from all buildings and property lines.

Amendment Reason:

We need to update the site drawing and change the size of the tanks to 8' diameter.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive Pekin, IL 61554	Contact Person: Bryan Estes Phone: 309/678-8061 Email: pcarrabbia@iome.com Contractor License # IL1293 Exp. 2/4/2028

Sincerely,



Daniel Starks

For Office Use Only

Dispenser Diesel Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

Dispenser Gas Equipment

Equipment Type	Permit Equipment	Action
-----------------------	-------------------------	---------------