



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 312/745-3162
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Extended

FOR OFFICE USE ONLY	
Facility #:	2040091
Permit #:	00438-2025REM
Request Rec'd:	04/11/2025
Approval Date:	04/11/2025 SK
Extension Date:	03/18/2026
Permit Expires:	10/14/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176 . The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Costco Wholesale Corporation P.O. Box 35005 Seattle, WA 98124 (None) County Contact: Jay Grubb 425/251-6222	FACILITY - name and address where tanks are located: Costco Gasoline #380 2746 N. Clybourn Avenue Chicago, IL 60614 Cook County Contact: Dennis Bock 425/313-8100
---	--

IEMA Number
2000-0918

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
3	20,000	Gasoline - Regular	
4	20,000	Gasoline - Regular	
5	20,000	Gasoline - Premium	

Summary of Work

Removing existing 3" over 2" double wall fiberglass vent line from (3) different tanks.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@andersonpump.com Contractor License # IL002275 Exp. 6/10/2025

Sincerely,

Sean Keane