



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov  
**Extended/Amended**

FOR OFFICE USE ONLY	
Facility #:	2014604
Permit #:	01246-2025UPG
Request Rec'd:	09/22/2025
Approval Date:	09/23/2025 DS
Amended Date:	12/22/2025 DS
Extension Date:	03/18/2026
Permit Expires:	09/24/2026

### **Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: 3005 Kirchoff, LLC 7105 N. Keating Lincolnwood, IL 60712 (None) County Contact: Faris Saleh 773/920-8379	<b>FACILITY</b> - name and address where tanks are located: 3005 Kirchoff, LLC 3005 Kirchoff Road Rolling Meadows, IL 60008 Cook County 02-36-105-021-0000 Contact: Faris Saleh 773/920-8379
--	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Out of service	Federal
2	Gasoline - Regular	10,000	Out of service	Federal
3	Gasoline - Premium	10,000	Out of service	Federal
4	Gasoline - Premium	6,000	Out of service	Federal
5	Diesel Fuel	6,000	Out of service	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Removing
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Leak Detection - Piping	Mechanical Other Non-vented check valve	New
Leak Detection - Piping	Siphon Bar	Removing
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Removing
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing
Leak Detection - Piping	Mechanical Other Non-vented check valve - South	New
Leak Detection - Piping	Siphon Bar	Removing
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Removing
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing
Leak Detection - Piping	Mechanical Other Non-vented check valve	New
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Removing
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing
Leak Detection - Piping	Mechanical Other Non-vented check valve	New
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive - Northeast	New
Corrosion Protection - Piping	Flexible Non-Corrosive - North	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - European with No Test Req Suction
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9	Sump / Sensors Changing
11/12	New

### Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

### Dispenser 9 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser 11/12 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Summary of Work**

Entire forecourt under the canopy will be removed and replaced including new UDCs with sensors and new islands. Tanks will be fitted with new tank sumps with sensors and new submersible motors. Regular tanks siphon will be removed and tanks will be manifolded at the submersible motors. The Premium tanks siphon will be removed and tanks will be manifolded at the submersible motors.

The Diesel tank will be fitted with a new tank sump, converted to a pressurized system from suction and have a submersible motor installed with electronic line leak detection and a sump sensor.

All fuel supply piping to be replaced with double-wall flexible APT piping.

**Special Contingencies**


**NOTE: Replacement of the tank monitor will be like for like**

**Amendment Reason:**

Replacing existing Veeder-Root TLS-350 console with a newer refurbished TLS-350 console with CSLD.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: jim.veverka@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks

For Office Use Only		
<b>Tank 1 Equipment</b>		
Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing
<b>Tank 2 Equipment</b>		
Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing
<b>Tank 3 Equipment</b>		
Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing
<b>Tank 4 Equipment</b>		
Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing
<b>Tank 5 Equipment</b>		
Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

**Dispenser 1/2 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

**Dispenser 3/4 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

**Dispenser 5/6 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

**Dispenser 7/8 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

**Dispenser 9 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall UDC Sump	Removing

**Dispenser 11/12 Equipment**

<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
-----------------------	-------------------------	---------------