



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	5029235
Permit #:	00303-2026UPG
Request Rec'd:	03/18/2026
Approval Date:	03/19/2026 DS
Permit Expires:	09/21/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          J. D. Streett &amp; Company, Inc.          144 Weldon Parkway          Maryland Heights, MO 63043          Contact: Darrell Meek 314/580-1191</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          Virden Fast Stop          1304 N. Springfield St., Rt. 4          Virden, IL 62690          Macoupin County          Contact: David Wright 217/965-3403</p>
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Mid-grade	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal
4	Diesel Fuel	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket Insert

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket Insert

**Summary of Work**

upgrading all four tanks to double wall spill buckets. Replacing the riser on tank 4 as straight drop tube is stuck.

**Special Contingencies**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

UPC Enterprises, LC d/b/a United Petroleum Service  
128 Millwell Drive  
Maryland Heights, MO 63043

Contact Person: Terry Smith  
Phone: 314/241-3767  
Email: cbayne@unitedpetro.com  
Contractor License # IL002402 Exp. 2/10/2028

Sincerely,

  
\_\_\_\_\_

Daniel Starks