



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2007972
Permit #: 00306-2026UPG
Request Rec'd: 03/20/2026
Approval Date: 03/22/2026 DS
Permit Expires: 09/22/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: AT&T Corp. 311 S. Akard Street, Room 12 Dallas, TX 75202 (None) County Contact: Lisa Espinosa 800/566-9347	FACILITY - name and address where tanks are located: Winnetka CO 794 Oak Street Winnetka, IL 60093 Cook County Contact: Environmental Management 877/648-2073
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	2,500	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Remove existing single wall spill bucket and install double wall spill bucket.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2028

Sincerely,

Daniel Starks