



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	1003663
Permit #:	00323-2026UPG
Request Rec'd:	03/25/2026
Approval Date:	03/26/2026 DS
Permit Expires:	09/28/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mid American Oil Company 2590 Biltmore Circle Aurora, IL 60503 Will County Contact: Baljit Sidhu 630/862-0941	<b>FACILITY</b> - name and address where tanks are located: Princeton Fast Stop 720 N. Main St. Princeton, IL 61356 Bureau County 1003663 Contact: Manish Patel 815/872-0706
---	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Gasoline - Regular	10,000	Currently in use	Federal
11	Gasoline - Regular	6,000	Currently in use	Federal

**Dispensers on the Permit**

Dispenser	Action
1/2	Replacing - 1/2
3/4	Replacing - 3/4
5/6	Replacing - 5/6
7/8	Replacing - 7/8

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

## Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

### Summary of Work

Replacing 4 dispensers. Regular line has manifold under dispenser #3/4 in sump above shear valves, disconnecting piping to move manifold under shear valves.

### Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2028

Sincerely,



---

Daniel Starks