



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2043949  
Permit #: 00367-2026UPG  
Request Rec'd: 04/02/2026  
Approval Date: 04/02/2026 DS  
Permit Expires: 10/02/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |   |
|--|---|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Penske Truck Leasing Co., LP<br>Route 10 Green Hills<br>Reading, PA 19603<br>Contact: Morgan McCusker 610/775-6409 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Penske Truck Leasing Co., L.P.<br>1200 Busse Rd.<br>Elk Grove Village, IL 60007<br>Cook County<br>08-27-402-053-0000<br>Contact: Tim Carolan 610/603-8450 |
|--|---|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2      | Gasoline - Regular | 12,000   | Currently in use | Federal          |

**Tank 2 Equipment**

| Equipment Type             | Permit Equipment         | Action  |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Spill Containment Device   | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

**Summary of Work**

The drop tube is seized so replacing the drop tube and spill bucket

**Special Contingencies**

|  |  |
|--|--|
| <b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  |  |
| America Petropump Services LLC d/b/a Ampsco Services<br>4075 Fox Valley Center Dr., Unit 9<br>Aurora, IL 60504 | Contact Person: Ravindra Penmatsa<br>Phone: 312/286-6722<br>Email: ravi@ampsco.net<br>Contractor License # IL002420 Exp. 5/22/2027 |

Sincerely,

Daniel Starks