



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Replacement of 00416-2025INS

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2047867 |
| Permit #: | 00389-2026INS |
| Request Rec'd: | 04/08/2026 |
| Approval Date: | 04/09/2026 DS |
| Permit Expires: | 10/09/2026 |

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| <p>OWNER OF TANKS - Corporation, partnership, or other business entity: QuikTrip Corporation 4705 South 129th East Ave. Tulsa, OK 74134 Contact: Victoria K Hensley 918/615-7304</p> | <p>FACILITY - name and address where tanks are located: QuikTrip #4404 501 N Ridge Rd Minooka, IL 60447 Grundy County 09-35-400-015-0000 Contact: Kyla Rudd 918/615-7304</p> |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|----------------------|------------------|
| 1 | Gasoline - Regular | 20,000 | Installed/Not in Use | Federal |
| 2 | Gasoline - Regular | 20,000 | Installed/Not in Use | Federal |
| 3 | Gasoline - Regular | 20,000 | Installed/Not in Use | Federal |
| 4 | E15 | 20,000 | Installed/Not in Use | Federal |
| 5 | Gasoline - Premium | 20,000 | Installed/Not in Use | Federal |
| 6 | B-99 | 17,000 | Installed/Not in Use | Federal |
| 7 | Diesel Fuel | 30,000 | Installed/Not in Use | Federal |
| 8 | Diesel Fuel | 30,000 | Installed/Not in Use | Federal |
| 9 | Diesel Fuel | 30,000 | Installed/Not in Use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Piping | Siphon Bar | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↪ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↪ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Piping | Siphon Bar | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↪ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↪ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Piping | Siphon Bar | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Blending Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Blending Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Blending Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|--|--------|
| Corrosion Protection - Piping | Flexible Non-Corrosive | New |
| Corrosion Protection - Tank | Fiberglass Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Blending Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Flexible Double Wall OPW Flexworks | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Piping | Single Wall Transition Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Fiberglass Brine Filled Double Wall Containment Solutions | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|--------|
| 1/2 | New |
| 1D/2D | New |
| 2D/3D | New |
| 3/4 | New |
| 3D/4D | New |
| 4D/5D | New |
| 5/6 | New |
| 5D/6D | New |
| 6D/7D | New |
| 7/8 | New |
| 7D/8D | New |
| 9/10 | New |
| 11/12 | New |
| 13/14 | New |
| 15/16 | New |
| 17/18 | New |
| 19/20 | New |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 1D/2D Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 2D/3D Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 3D/4D Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 4D/5D Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 5D/6D Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 6D/7D Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|---------------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 7D/8D Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 13/14 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 15/16 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 17/18 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 19/20 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New |

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions. There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

Installing (5) 20K tanks, (1) 17K tank, (3) 30K tanks, and (1) 10K DEF tank. 2 canopies, OPW flex works piping, PCI tank sumps, bravo dispenser sumps, TLS450+. The auto and diesel tanks will have a sump vent system piped through them with ball floats on each end.

Special Contingencies


NOTE: Vents must meet section 175.440 of our rules.

Replacement Reason:

Expired and still need

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|---|
| Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108 | Contact Person: Robert Stenstrom Phone: 630/606-0996 Email: nickb@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2028 |

Sincerely,



Daniel Starks