



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2001847
Permit #:	00392-2026UPG
Request Rec'd:	04/08/2026
Approval Date:	04/09/2026 DS
Permit Expires:	10/09/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Lake Zurich Community Unit School District 95 832 S. Rand Road Lake Zurich, IL 60047 Lake County Contact: Lyle Erstad 847/540-3414</p>	<p>FACILITY - name and address where tanks are located: Lake Zurich Community Unit School District 95 100 - 120 Church Street Lake Zurich, IL 60047 Lake County 14-17-400-014 Contact: Lyle Erstad 847/540-3414</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Ultra Low Sulfur Diesel	8,000	Currently in use	Federal

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Other Non-vented check valve	New

Summary of Work

Replacing check valve under diesel pump.

Special Contingencies

NOTE: Site has european suction, therefore a sump is not mandatory at the tank, only at the dispensers.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 600903936	Contact Person: Warren Cherner Phone: 847/465-4000 Email: info@metrotank.com Contractor License # IL102 Exp. 2/9/2028

Sincerely,



Daniel Starks