



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 312/745-3162
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2000800 |
| Permit #: | 00395-2026UPG |
| Request Rec'd: | 04/09/2026 |
| Approval Date: | 04/09/2026 SK |
| Permit Expires: | 10/09/2026 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Lakhani & Sons Inc 7138 N Sheridan Chicago, IL 60626 Cook County Contact: Minhaz Lakhani 312/582-5587 | FACILITY - name and address where tanks are located: Rogers Park Citgo 7138 N. Sheridan Rd. Chicago, IL 60626 Cook County Contact: Minhaz S Lakhani 312/582-5587 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Summary of Work

Replacing the Regular North (T1) single wall spill container with a double wall spill container

Special Contingencies

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: DJ White Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2028 |

Sincerely,

Sean Keane