



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2013279
Permit #:	00407-2026UPG
Request Rec'd:	04/13/2026
Approval Date:	04/13/2026 DS
Permit Expires:	10/14/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061 Lake County Contact: Raymond Kirchner 847/837-0777	FACILITY - name and address where tanks are located: Glenview Quik Shop 750 Waukegan Road Glenview, IL 60025 Cook County Contact: Ashok Patel 847/837-0777
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Extractor Fitting Valves	New
Piping	Flexible Single Wall Piping	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Extractor Fitting Valves	New
Piping	Flexible Single Wall Piping	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Extractor Fitting Valves	New
Piping	Flexible Single Wall Piping	New

Summary of Work

Replacing / Relocating vent lines. Installing OPW extractor fittings, and 2" Nupi s/w vent lines.

Special Contingencies

NOTE: Vents must meet section 175.440 of our rules

PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: 224/476-4367
Email: tk@perftank.com
Contractor License # IL881 Exp. 12/8/2026

Sincerely,



Daniel Starks