



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 312/745-3162  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2022007
Permit #:	00398-2026UPG
Request Rec'd:	04/10/2026
Approval Date:	04/13/2026 SK
Permit Expires:	10/14/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: General Ser Administration 230 S Dearborn Chicago, IL 60604 Cook County Contact: Public Bldg. Service 312/353-3607	<b>FACILITY</b> - name and address where tanks are located: Harold Washington SSA Ctr. 600 W Madison Chicago, IL 60661 Cook County Contact: Ron Lanser 312/575-5540
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	6,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel iTouch
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

**Summary of Work**

Beacon SSI, Inc. is replacing the existing OPW ATG and Tank Interstitial Sensor with Omntec OEL8000IIK4P-5 Proteus-K ATG, Omntec Magnetostrictive Steel Probe and Omntec LF-DWF DW Tank Interstitial Sensor.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2027

Sincerely,  
  
Sean Keane