



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3002590
Permit #:	00413-2026CAT
Request Rec'd:	04/13/2026
Approval Date:	04/14/2026 DS
Permit Expires:	10/14/2026

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
Guraya, Inc. 1009 Division Street Orion, IL 61273 Henry County Contact: Harbhajan Singh 309/314-3707	Station #1195 1009 Division Street Orion, IL 61273 Henry County Contact: Partap Singh 262/242-4800

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Diesel Fuel	4,000	Currently in use	Federal
12	Gasoline - Premium	4,000	Currently in use	Federal

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

**NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks**

Special Contingencies

Summary of Work
REPLACING DEPLETED OR MISSING ANODES

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/344-0700 Email: rob@pipecoinc.com Contractor License # IL2034 Exp. 9/28/2026

Sincerely,

Daniel J. Starks

Daniel Starks