



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2008881
Permit #:	00414-2026CAT
Request Rec'd:	04/14/2026
Approval Date:	04/14/2026 DS
Permit Expires:	10/14/2026

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Amcor Flexibles 1919 Butterfield Rd. Mundelein, IL 60060 Lake County Contact: Brett Harris 847/362-9000	FACILITY - name and address where tanks are located: Amcor Flexibles 1919 S Butterfield Rd Mundelein, IL 60060 Lake County Contact: Phil Hermano 847/343-2264
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Alcohol	2,000	Currently in use	Federal
3	Methyl Ethyl Ketone	2,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	New

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Rick's design: 40V/5A rectifier, 2 anodes, 150 lbs coke breeze, 6 circuit J Box bonding to the tanks tops,. The existing sac anodes must be disconnected.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 512/380-7117 Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 3/20/2028

Sincerely,

Daniel J. Starks

Daniel Starks