



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2045977
Permit #:	00423-2026UPG
Request Rec'd:	04/17/2026
Approval Date:	04/17/2026 DS
Permit Expires:	10/19/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          Speedway, LLC          P.O. Box 1500          Springfield, OH 45501          Clark County          Contact: Zachery Davis 937/203-7827</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          Speedway Store #6207          1495 East Wilson St.          Batavia, IL 60510          Kane County          12-24-126-011          Contact: Store Manager 630/406-0241</p>
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	E85	8,000	Currently in use	Federal
2	Gasoline - Premium	4,000	Currently in use	Federal
3	B-11	12,000	Currently in use	Federal
4	Gasoline - Regular	20,000	Currently in use	Federal
5	Gasoline - Regular	20,000	Currently in use	Federal
6	B-11	20,000	Currently in use	Federal
7	B-11	20,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

#### Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South
Piping	Other Fiberglass Riser	New
Spill Containment Device	Double Wall Spill Bucket - North	Replacing - Spill Contain Device - Single Wall Spill Bucket - North

#### Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South

#### Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South

#### Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve - North	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Overfill Prevention Device	Overfill Drop Tube Valve - South	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - South

#### Summary of Work

Regular Tank# 4 = Installing (1) New Fill Riser, Replacing (1) Overspill bucket and (2) Overfill drop tubes  
Tank 1 E85, Tank 2 Premium, Tank 3 B-11, Tank 5 Regular, Tank 6 B-11, and Tank 7 B-11 = Replacing All the Overfill drop tubes

#### Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

  
\_\_\_\_\_

Daniel Starks