



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2048008
Permit #:	00448-2026ABN
Request Rec'd:	04/22/2026
Approval Date:	04/23/2026 DS
Permit Expires:	10/23/2026

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Combined Metals Company, LLC 2401 W. Grant Avenue Bellwood, IL 60104 Contact: Brian LeMaster 815/751-5108</p>	<p>FACILITY - name and address where tanks are located: Combined Metals Company, LLC 2401 W. Grant Avenue Bellwood, IL 60104 Cook County 15-10-112-036 Contact: Brian LeMaster 815/751-5108</p>
--	--

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	6,000	#2 Fuel Oil	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

UST proximity to the building foundations could cause damage to remove.

Location of Tanks Being Abandoned

UST proximity to the building foundations could cause damage to remove.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>RW Collins Company 7225 West 66th Street Chicago, IL 60638</p>	<p>Contact Person: Lisa Kruse Phone: 312/505-6763 Email: alock@rwcollins.com Contractor License # IL772 Exp. 2/9/2028</p>

Sincerely,

Daniel Starks