



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2007483
Permit #:	00461-2026UPG
Request Rec'd:	04/24/2026
Approval Date:	04/27/2026 DS
Permit Expires:	10/27/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Lehigh Gas Wholesale Services Inc. 645 Hamilton, Suite 400 Allentown, PA 18101 (None) County Contact: Shibu Joseph 610/625-8061	FACILITY - name and address where tanks are located: IL0079 2551 N. Route 12 Spring Grove, IL 60081 McHenry County 04-25-400-009 Contact: Pritech Patel 847/680-5831
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Kerosene	4,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Gasoline - Regular	12,000	Currently in use	Federal
4	Gasoline - Regular	12,000	Currently in use	Federal
5	Diesel Fuel	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Install new STP tank tops sumps where none previously existed.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2028

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing