



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2040156
Permit #: 00471-2026REM
Request Rec'd: 04/27/2026
Approval Date: 04/27/2026 DS
Permit Expires: 10/27/2026

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710 | FACILITY - name and address where tanks are located: Romeoville #202 418 N. Weber Road Romeoville, IL 60446 Will County Contact: MALLORY SEFRHANS 847/223-3710 |
|--|---|

Tanks on the Permit For Piping Only

| Tank # | Capacity | Product | Last Used Date |
|--------|----------|-------------|----------------|
| 4 | 6,000 | Diesel Fuel | |

Summary of Work

We will be removing the existing DSL piping and replacing with DW Nupi Smartflex piping and extending it to a relocated DSL UDC and (1) new DSL UDC as shown on plans.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191 | Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 3/8/2027 |

Sincerely,



Daniel Starks