



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2040156
Permit #:	00472-2026UPG
Request Rec'd:	04/27/2026
Approval Date:	04/27/2026 DS
Permit Expires:	10/27/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710	FACILITY - name and address where tanks are located: Romeoville #202 418 N. Weber Road Romeoville, IL 60446 Will County Contact: MALLORY SEFRHANS 847/223-3710
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	6,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Piping	Flexible Double Wall NUPI Smartflex - South	Replacing - Piping - Flexible Double Wall Environ Geo Flex
Piping	Other Submersible Pump	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
17/18	Sump / Sensors Changing
19/20	New

Dispenser 17/18 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

Dispenser 19/20 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

Removing Diesel dispenser #17/18 and RUL / PUL dispenser #3/4 from the existing island. Constructing new concrete island at the existing UDC for RUL / PUL dispenser #3/4. Removing the existing UDC & piping for DSL dispenser #17/18. Installing new UDC for DSL #17/18 relocated as shown on drawing. Installing (1) additional DSL UDC for (1) additional DSL dispenser (#19/20) at South end of canopy as shown on drawing. Replacing the existing DSL STP with new FE Petro 2HP Ap Series STP. Replacing the DSL piping from the existing SW STP Sump to both new DSL UDC's. Install (2) new DSL Dispensers.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2026

Sincerely,



Daniel Starks