



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 2020663 |
| Permit #: | 00505-2026UPG |
| Request Rec'd: | 05/04/2026 |
| Approval Date: | 05/04/2026 DS |
| Permit Expires: | 11/04/2026 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: A&E Holding, LLC 66 Caribou Crossing Northbrook, IL 60062 Cook County Contact: Savi Singh 847/845-2020 | FACILITY - name and address where tanks are located: Antioch Citgo 41082 North Highway 83 Antioch, IL 60002 Lake County 02-17-306-017 Contact: Savi Singh 773/710-0991 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 5 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 6 | Gasoline - Premium | 10,000 | Currently in use | Federal |
| 7 | Diesel Fuel | 10,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection - Wireless | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection - Wireless |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection - Wireless | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection - Wireless |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Mechanical Pressurized Line Leak Detection - Wireless | Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection - Wireless |

Summary of Work

Replacing WPLLD electronic leak detection with mechanical leak detection on all 3 lines.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
415 W. Golf Rd. Unit 28M-N
Arlington Heights, IL 60005

Contact Person: Chris Derro
Phone: 708/717-2676
Email: cderro@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2027

Sincerely,



Daniel Starks