



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3018411
Permit #: 00509-2026REM
Request Rec'd: 05/05/2026
Approval Date: 05/05/2026 DS
Permit Expires: 11/05/2026

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176 . The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Moline Forge, Inc. 4101 4th Avenue Moline, IL 61265 Rock Island County Contact: Victor Almgren 309/762-5506</p>	<p>FACILITY - name and address where tanks are located: Moline Forge, Inc. 4101 4th Avenue Moline, IL 61265 Rock Island County 08-34-205-002 Contact: Vic Almgren 309/762-5506</p>
--	---

IEMA Number
2025-0347

Tanks on the Permit

Tank #	Capacity	Product	Last Used Date
1	20,000	Fuel Oil	12/02/2025
2	20,000	Fuel Oil	12/02/2025

Summary of Work

2- 20,000 gallon STIP3 tanks to be removed along with the feed and return lines that run from the tanks to the building. The tanks contained heating oil for lighting the Forge furnaces. ATG system to be removed. All fuel lines inside the building to remain intact as they are now being utilized in the new AST system that has already been approved by the State and is currently in use.

Special Contingencies

The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Illowa Enterprises, Inc. 2703 4th Avenue Moline, IL 61265</p>	<p>Contact Person: James Saddoris Phone: 309/762-1729 Email: illowa@illowaent.com Contractor License # IL981 Exp. 5/1/2028</p>

Sincerely,

Daniel J. Starks

Daniel Starks