



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

| | |
|----------------------------|---------------|
| FOR OFFICE USE ONLY | |
| Facility #: | 3038392 |
| Permit #: | 00517-2026UPG |
| Request Rec'd: | 05/06/2026 |
| Approval Date: | 05/06/2026 DS |
| Permit Expires: | 11/06/2026 |

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| <p>OWNER OF TANKS - Corporation, partnership, or other business entity: Mihir Properties, LLC 319 Main Street Maquon, IL 61458 (None) County Contact: Manthankumar Joshi 872/800-7722</p> | <p>FACILITY - name and address where tanks are located: Maquon Miracle Mart 319 Main Street Maquon, IL 61458 Knox County 19-04-211-013 Contact: Manthankumar Joshi 872/800-7722</p> |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--------------------------|---|
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Summary of Work

Replacing spill containment manhole due to failed testing. Replacing overfill drop tube due to failed testing.

Special Contingencies

NOTE: NOV must be complied at the time of this permitted work

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Total Petroleum Service Company 2421 Washington Road Washington, IL 61571 | Contact Person: Cheri McCoy Phone: 309/694-8224 Email: tom.oltman@totalpetroleum.net Contractor License # IL1079 Exp. 2/8/2028 |

Sincerely,

Daniel Starks