



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	3001248
Permit #:	00518-2026UPG
Request Rec'd:	05/06/2026
Approval Date:	05/06/2026 DS
Permit Expires:	11/06/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Sabry A. Malahee 425 Derby Street Pekin, IL 61554 Tazewell County Contact: Sabry Malahee 312/539-3771	<b>FACILITY</b> - name and address where tanks are located: Derby BP 425 Derby Street Pekin, IL 61554 Tazewell County 40-10-03-414-027 Contact: Sabry Malahee 312/539-3771
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Diesel Fuel	8,000	Currently in use	Federal

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

Replacing spill manhole due to drop tube valve failing triennial testing and inability to remove valve from spill manhole.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: tom.oltman@totalpetroleum.net Contractor License # IL1079 Exp. 2/8/2028

Sincerely,

Daniel Starks