



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2023046
Permit #:	00519-2026UPG
Request Rec'd:	05/06/2026
Approval Date:	05/06/2026 DS
Permit Expires:	11/06/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

<p>OWNER OF TANKS - Corporation, partnership, or other business entity: Ananyata Corporation 700 Waukegan Rd. Deerfield, IL 60015 Lake County Contact: Mukesh Bhatia 630/660-6854</p>	<p>FACILITY - name and address where tanks are located: Exxon 700 Waukegan Road Deerfield, IL 60015 Lake County 16-33-101-020 Contact: Mukesh Bhatia 630/660-6854</p>
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket


Summary of Work

The drop tube failed inspection so replacing the spill bucket. Will replace drop tube also if needed

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2027

Sincerely,



Daniel Starks