



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	6022607
Permit #:	00526-2026CAT
Request Rec'd:	05/07/2026
Approval Date:	05/07/2026 DS
Permit Expires:	11/09/2026

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: GPM Midwest 18, LLC 8565 Magellan Pkwy, Ste. 400 Richmond, VA 23227 (None) County Contact: Amanda Gapski 317/914-9446	FACILITY - name and address where tanks are located: Fas Mart #557 491 Franklin St. Carlyle, IL 62231 Clinton County 08-08-18-372-010 Contact: Chad Fluck 317/914-9446
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Kerosene	1,000	Currently in use	Federal
6	Gasoline - Regular	10,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Install two 20-pound high potential magnesium anodes through a mini test station on each of the regular and kerosene tanks

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 512/380-7117 Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 3/20/2028

Sincerely,

Daniel J. Starks

Daniel Starks