



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2024612
Permit #:	00531-2026UPG
Request Rec'd:	05/11/2026
Approval Date:	05/11/2026 DS
Permit Expires:	11/12/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Casey's #6524 1400 N. Arlington Heights Road Itasca, IL 60143 Du Page County 03-05-200-039 Contact: Jill Reams-Widder 515/446-6238
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Premium	12,000	Currently in use	Federal
8	Diesel Fuel	8,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New

Summary of Work

Tank# 7 Premium and Tank# 8 Diesel = Installing new Interstitial Sensor Risers

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: Keith@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Daniel Starks