



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2018874
Permit #:	00537-2026UPG
Request Rec'd:	05/13/2026
Approval Date:	05/13/2026 DS
Permit Expires:	11/13/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: RDK Ventures LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County Contact: Michele Alvarado 773/456-5280	<b>FACILITY</b> - name and address where tanks are located: Circle K #6893 1001 W. Route 34 Plano, IL 60178 Kendall County 01-28-227-015 Contact: Michele Alvarado 708/748-3496
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Premium	10,000	Currently in use	Federal
7	Gasoline - Regular	10,000	Currently in use	Federal
9	Diesel Fuel	10,000	Currently in use	Federal
10	Kerosene	4,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 9 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

## Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

### Summary of Work

Tanks# 6 - Premium, 7 - Regular, 9 - Diesel, and 10 - Kerosene = Installing new Fill Risers, Replacing Overspill buckets and Overfill drop tubes

### Special Contingencies

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ron Anderson  
Phone: 708/560-5590  
Email: Keith@Andersonpump.com  
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



---

Daniel Starks