



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	3046022
Permit #:	00550-2026UPG
Request Rec'd:	05/15/2026
Approval Date:	05/15/2026 DS
Permit Expires:	11/17/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          Hy-Vee, Inc.          5820 Westown Parkway          West Des Moines, IA 50266          Polk County          Contact: Amanda L. Judkins 515/267-2800</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          Hy-Vee Gas          1925 N Henderson St          Galesburg, IL 61401          Knox County          99-03-153-004          Contact: Tom Crouh 309/334-0825</p>
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	6,000	Currently in use	Federal
5	E85	6,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

- Saw cut, break, and remove concrete around E85 & Premium spill buckets, and adjacent manways
- ? Excavate to tank and remove riser, spill bucket, and drop tube
- ? Install new riser, spill bucket, drop tube, fill adapter, and cap
- ? Install new vapor adaptors and caps on E85 & Premium vapor risers
- ? Backfill to subgrade
- ? Set new manways
- ? Install rebar pins and pour concrete

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Evora Energy LLC          4405 SE Beisser Drive Suite 108          Grimes, IA 501115312</p>	<p>Contact Person: Abby Sellers          Phone: 309/945-3851          Email: jburton@evora-group.com          Contractor License # IL002474 Exp. 5/28/2027</p>

Sincerely,

*Daniel J. Starks*

Daniel Starks