



City of Chicago
Department of Environment
 2160 W. Ogden
 Chicago, IL 60612
 312/617-4550
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2023011
Permit #:	00569-2026UPG
Request Rec'd:	05/26/2026
Approval Date:	05/26/2026 SK
Permit Expires:	11/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Haddad Realty, LLC 210 Shadow Ridge Court Palos Park, IL 60457 Cook County Contact: Anssemoss Haddad 312/617-1243	FACILITY - name and address where tanks are located: BP 1004 S. Des Plaines Ave. Chicago, IL 60607 Cook County 17-16-322-062-0000 Contact: Joe Nahhas 312/617-1243
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

Breaking out Regular Tank #6 containment sump, insalling new submersible, ball valve, flex connector, and bravo single was containment sump.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@Andersonpump.com Contractor License # IL002275 Exp. 5/21/2028

Sincerely,

Sean Keane

For Office Use Only

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Required in Single Wall STP/Tanktop Sump	Removing