



City of Chicago
Department of Environment
 2160 W. Ogden
 Chicago, IL 60612
 312/617-4550
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2007050
Permit #:	00570-2026UPG
Request Rec'd:	05/26/2026
Approval Date:	05/26/2026 SK
Permit Expires:	11/28/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Minhaj Ahmed 5875 N. Lincolnwood, Suite 130 Chicago, IL 60659 Cook County Contact: Lametrus Thomas 312/286-9677	FACILITY - name and address where tanks are located: Tumara Food Mart Inc.(Citgo) 2941 E. 83rd Street Chicago, IL 60617 Cook County Contact: Ahmed Minhaj 312/286-9677
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	4,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Summary of Work

Replacing #1/2 Diesel shear valve.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027

Sincerely,

Sean Keane