



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	4011115
Permit #:	00598-2026UPG
Request Rec'd:	05/28/2026
Approval Date:	05/28/2026 DS
Permit Expires:	12/02/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Shane Maxey 618/233-6754	FACILITY - name and address where tanks are located: Shelbyville Motomart 1003 Main Street Shelbyville, IL 62565 Shelby County Contact: Rose Coleman 217/774-5710
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	10,000	Currently in use	Federal
5	Gasoline - Mid-grade	10,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown - West	Replacing - Leak Detect - Piping - Piping Sump Sensors Not Regulated
↳ Leak Detection - Piping	Sump Sensor with positive shutdown - East	Replacing - Leak Detect - Piping - Sump Sensor

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown - South	Replacing - Leak Detect - Piping - Piping Sump Sensors Not Regulated
↳ Leak Detection - Piping	Sump Sensor with positive shutdown - North	Replacing - Leak Detect - Piping - Sump Sensor


Summary of Work

Replace all 3 STP sumps & make water tight

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: 812/425-4137 Email: jerra@hci4.com Contractor License # IL646 Exp. 4/2/2028

Sincerely,



Daniel Starks