



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-021508
Permit # 01580-2006FLX
Request Rec'd 10/17/2006
Amended Date
Approval Date 10/24/2006 DS
Permit Expires 4/24/2007

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Fire King Ser Station Inc 1901 Elston Ave Chicago, IL 60622 Contact: Walzer Irwin (312) 772-4095	(2) FACILITY - name and address where tanks are located: Norridge Citgo Ser 8500 W Lawrence Ave Norridge, Cook Co., IL Contact: Quershi Qamar (312) 453-9637
--	---

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:


- (a) Number and size of tanks being upgraded or repaired:* (TK # 7, 8, 9) - 10,000 gallons
- (b) Type of flex connector(s):* (TK # 7, 8, 9) - Existing steel flex connectors
- (c) Product stored in each tank:* (TK # 7, 8, 9) - Gasoline
- (d) Corrosion Protection being installed with flex connector(s):* (TK # 7, 8, 9) - (Installing) Sacrificial anodes cathodic protection (TK # 7, 8, 9) - Installing anodes to flexes in submersibles only

- (4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

- (5) SPECIAL CONTINGENCIES:** A Timely Compliance Opportunity letter was issued for this site on 9/21/06 allowing this facility 60 days to come into compliance. If compliance is not achieved by 11/20/06 the non-compliant underground storage tank(s) will be red-tagged.

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> US Tank Protectors Inc Downers Grove, IL 60515	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)