



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 4011115
Permit #: 00598-2026UPG
Request Rec'd: 05/28/2026
Approval Date: 05/28/2026 DS
Amended Date: 05/30/2026 DS
Permit Expires: 12/02/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Shane Maxey 618/233-6754	FACILITY - name and address where tanks are located: Shelbyville Motomart 1003 Main Street Shelbyville, IL 62565 Shelby County Contact: Rose Coleman 217/774-5710
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	10,000	Currently in use	Federal
5	Gasoline - Mid-grade	10,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown - North	Replacing - Leak Detect - Piping - Piping Sump Sensors Not Regulated
Leak Detection - Piping	Sump Sensor with positive shutdown - East	Replacing - Leak Detect - Piping - Sump Sensor
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown - West	Replacing - Leak Detect - Piping - Piping Sump Sensors Not Regulated
Leak Detection - Piping	Sump Sensor with positive shutdown - South	Replacing - Leak Detect - Piping - Sump Sensor
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket

Summary of Work

Replace all 3 STP sumps & make water tight

May need to install new spill buckets at site, didn't want to have to stop working to file new permit

Special Contingencies

Amendment Reason:


Need to request permission to install new Doublewallll spill buckets if needed

PERSON, FIRM OR COMPANY PERFORMING WORK:

Hinderliter Construction & Maint., Inc.
3601 North St. Joseph Avenue
Evansville, IN 47720

Contact Person: Mark Hinderliter
Phone: 812/425-4137
Email: jerra@hci4.com
Contractor License # IL646 Exp. 4/2/2028

Sincerely,



Daniel Starks