



**City of Chicago**  
**Department of Environment**  
 2160 W. Ogden  
 Chicago, IL 60612  
 312/617-4550  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2017656
Permit #:	00614-2026REM
Request Rec'd:	06/02/2026
Approval Date:	06/02/2026 SK
Permit Expires:	12/02/2026

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances**

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176 . The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachery Davis 937/203-7827	<b>FACILITY</b> - name and address where tanks are located: Speedway #8309 2303 S. Western Ave. Chicago, IL 60608 Cook County 17-30-108-002-0000 Contact: Store Manager 937/863-6513
--	---

**IEMA Number**  
 2019-1195

**Tanks on the Permit For Piping Only**

Tank #	Capacity	Product	Last Used Date
9	15,000	Gasoline - Regular	
10	10,000	Gasoline - Premium	
11	6,000	B-11	

**Summary of Work**

Removing existing piping, and associated vents for tanks 9,10,11. Leaving concrete over Kerosene tank 12 to remain existing.

**Special Contingencies**

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@Andersonpump.com Contractor License # IL002275 Exp. 6/10/2027

Sincerely,  
 Sean Keane