



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 5013931
Permit #: 00663-2026UPG
Request Rec'd: 06/10/2026
Approval Date: 06/14/2026 DS
Permit Expires: 12/15/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Madras Real Estate, LLC 2130 Kienlen Avenue St. Louis, MO 63121 (None) County Contact: Mike Madras 314/383-3700	FACILITY - name and address where tanks are located: Wally Hutter Oil Company d/b/a Haxel's Clark Station 1138 Maine Street Quincy, IL 62305 Adams County Contact: Mike Madras 314/383-3700
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	8,000	Currently in use	Federal
8	Gasoline - Premium	4,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

REPLACE SPILL BUCKETS ON UNLEADED AND PREMIUM TANK WITH DOUBLE WALL SPILL BUCKETS.
REPLACED THE OVERFILL DROP TUBE VALVE IN PREMIUM TANK.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305	Contact Person: Kevin Majors Phone: 217/223-2190 Email: kmajors@rlhoener.com Contractor License # IL2021 Exp. 5/22/2028

Sincerely,

Daniel Starks