



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2014717
Permit #: 00670-2026UPG
Request Rec'd: 06/15/2026
Approval Date: 06/15/2026 DS
Permit Expires: 06/26/2026

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County Contact: Michele Alvarado 773/456-5280	FACILITY - name and address where tanks are located: Circle K #6885 14301 South Wolf Road Orland Park, IL 60462 Cook County 27-08-100-056-0000 Contact: Tyler Kondziolka 630/800-6065
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	12,000	Currently in use	Federal
7	Diesel Fuel	12,000	Currently in use	Federal
8	Gasoline - Premium	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Vent	New

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Vent	New

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Vent	New

Summary of Work

NO PIPING IS BEING REPLACED : THERE IS NOT A DROP DOWN FOR "VENT PIPING FITTINGS"

Nicor bored into the vent lines, cracking them while performing work. We need to install Fiberglass Coupling sleeves around the cracks on all (3) vent lines. Once this is done, we will air test the vent lines and also have a 3rd party testing company perform a test.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/560-5590
Email: Keith@Andersonpump.com
Contractor License # IL002275 Exp. 5/21/2028

Sincerely,



Daniel Starks