



**City of Chicago**  
**Department of Environment**  
 2160 W. Ogden  
 Chicago, IL 60612  
 312/617-4550  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2048017
Permit #:	00685-2026ABN
Request Rec'd:	06/16/2026
Approval Date:	06/16/2026 SK
Permit Expires:	12/16/2026

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b>          - Corporation, partnership, or other business entity:          Chicago Public Schools          42 W. Madison Street          Chicago, IL 60602          Contact: Richard Schleyer 773/553-2900</p>	<p><b>FACILITY</b>          - name and address where tanks are located:          William C Reavis Math &amp; Science ES          834 East 50th Street          Chicago, IL 60615          Cook County          20-11-109-014-0000          Contact: Michael Gerardi 312/560-4052</p>
--	--

**Tanks on the Permit**

\* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	8,000	Heating Oil	Inert material mixed with portland cement

**Explanation of Waiver for Abandonment**

Abandon in place UST and associated tank piping due to high voltage electric duct bank <5' from end of the tank.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2028

Sincerely,

Sean Keane