



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7011104
Permit #: 00743-2026UPG
Request Rec'd: 06/26/2026
Approval Date: 06/29/2026 DS
Permit Expires: 12/29/2026

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Shane Maxey 618/233-6754	FACILITY - name and address where tanks are located: Pinckneyville Motomart 509 South Main Street Pinckneyville, IL 62274 Perry County Contact: Katie Leonard 618/357-3111
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Galvanized Steel Single Wall Piping	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Galvanized Steel Single Wall Piping	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump

Summary of Work

Install new single wall STP sumps on both UL tanks. The existing sumps are cracked on the bottom. Cut back the existing single wall FRP piping and conduits, set new sump into place, re-install the existing STP motors. re-pipe product lines to STP motor and reconnect conduit/wiring.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
128 Millwell Drive
Maryland Heights, MO 63043

Contact Person: Terry Smith
Phone: 314/267-1231
Email: terrys@unitedpetro.com
Contractor License # IL002402 Exp. 2/10/2028

Sincerely,



Daniel Starks