



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2023910
Permit #: 00761-2026CAT
Request Rec'd: 07/01/2026
Approval Date: 07/01/2026 DS
Permit Expires: 01/02/2027

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 6777 Lincoln Real Estate, Inc. 6777 N. Lincoln Ave. Lincolnwood, IL 60712 (None) County Contact: Binu Poonthurail 847/644-9869	FACILITY - name and address where tanks are located: 6777 Lincoln Real Estate, Inc. 6777 N. Lincoln Ave. Lincolnwood, IL 60646 Cook County 08-08-401-029-0000 Contact: Binu Poonthurail 847/644-9869
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal
4	Diesel Fuel	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Found during Annual Testing that Location does not have Cathodic Protection as Listed Per OSFM

PERSON, FIRM OR COMPANY PERFORMING WORK:

Midwest Tank Testing, LLC
2008 Medical Center Dr
Monticello, IL 61856

Contact Person: Stephen T. Hall
Phone: 217/714-4305
Email: Midwesttanktestingsth@aol.com
Contractor License # IL002461 Exp. 1/2/2028

Sincerely,



Daniel Starks