



City of Chicago
Department of Environment
2160 W. Ogden
Chicago, IL 60612
312/617-4550
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2041390
Permit #: 00771-2026REM
Request Rec'd: 07/06/2026
Approval Date: 07/06/2026 SK
Permit Expires: 01/06/2027

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Chicago S & A Inc 3153 West Chicago Avenue Chicago, IL 60620 Cook County Contact: Samir Khatib 708/906-7350	FACILITY - name and address where tanks are located: A A & S, Inc. 3153 West Chicago Avenue Chicago, IL 60622 Cook County Contact: Haitham Abdulrahman 773/722-9694
---	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	4,000	Diesel Fuel	
2	8,000	Gasoline - Premium	
3	12,000	Gasoline - Regular	

Summary of Work

Removing all existing containment and product pipe.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: DJ White Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 12/17/2027

Sincerely,

Sean Keane