



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4012375
Permit #: 00866-2026UPG
Request Rec'd: 07/23/2026
Approval Date: 07/23/2026 DS
Permit Expires: 01/25/2027

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: CP Tanks, LLC 811 W. Springfield Ave., Ste 201 Champaign, IL 61820 Champaign County Contact: Rolfe Lann 804/730-1568	FACILITY - name and address where tanks are located: Bowman Pantry 616 S. Bowman Ave. Danville, IL 61832 Vermilion County 23-16-105-010 Contact: Paul Singh 910/796-2436
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Out of service	Federal
6	Diesel Fuel	4,000	Out of service	Federal
7	Gasoline - Premium	4,000	Out of service	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve EBW 308

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve EBW 308

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve EBW 308

Summary of Work

Replacing (knocking out) the Ball float vent valves and installing new Overfill Drop Tubes for:

Tank #5 Gasoline-Regular (Installing OPW 61SO)

Tank #6 Diesel Fuel (Installing Franklin Fueling Defender)

Tank #7 Gasoline-Premium (Installing OPW 71SO)

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Hall's Maintenance Service LLC
6724 N Cantrall Creek Rd
Cantrall, IL 626258773

Contact Person: Michael Hall
Phone: 217/899-1334
Email: hallsmaintenanceservice77@gmail.com
Contractor License # IL002477 Exp. 5/7/2028

Sincerely,



Daniel Starks