



City of Chicago
Department of Environment
2160 W. Ogden
Chicago, IL 60612
312/617-4550
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2021471
Permit #: 00917-2026ABN
Request Rec'd: 08/05/2026
Approval Date: 08/05/2026 SK
Permit Expires: 02/05/2027

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: AB Marathon, Ltd. 550 N. Ashland Chicago, IL 60640 Cook County Contact: Aladin Khamis 773/447-4330	FACILITY - name and address where tanks are located: AB Marathon 5550 N. Ashland Chicago, IL 60640 Cook County Contact: Aladin Khamis 773/784-6400
--	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
4	2,000	Gasoline - Regular	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

UST #4 will be abandoned in place due to proximity to active USTs and building.

CONTAMINATED SITE!

IEMA Number

2026-0653

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 708/308-8217 Email: ademauro@rwcollins.com Contractor License # IL772 Exp. 2/9/2028

Sincerely,

Sean Keane