



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7041764
Permit #: 00940-2026UPG
Request Rec'd: 08/10/2026
Approval Date: 08/10/2026 DS
Permit Expires: 02/10/2027

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: A2 IL Investments, LLC 113 W Green Street Centralia, IL 62801 Marion County Contact: Asif Hemdani 846/216-2408	FACILITY - name and address where tanks are located: Wayne City Gas N Go LLC d/b/a DJ Mart 6 107 N. Main Wayne City, IL 62895 Wayne County 19-97-057-009 Contact: Asif Hemdani 845/216-2408
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing the spill bucket to double wall and removing the ball float and installing a overfill drop tube.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2028

Sincerely,

Daniel Starks